

HARMSCO®

Cleaning & Sanitizing Guide

For All-Poly/High Purity Cartridges

Cleaning

Use the following cleaning agents for cleaning filter cartridges. Immerse with cartridge open end up and soak in a container that has the prescribed concentration of the agent for at least 30 minutes.

- ▶ **Triton X-100:** add 15 drops of Triton X to one gallon (3.79 liters) of warm water and then mix well. Triton X is made by Roche Diagnostics.
- ▶ **LiquiNox/Alconox:** follow instructions provided by manufacturer on product packaging.
- ▶ **Minnclean TF:** add 30 grams of Minnclean to one gallon (3.79 liters) of warm water and mix well.

Sanitizing

Use the following sanitizing agents to properly sanitize cartridges prior to use in critical applications. Immerse with cartridge open end up and soak in the prescribed concentration of the agent for 30-60 minutes. For proper and effective sanitization raise the mixture's temperature to 80°F (27°C).

- ▶ **Sodium Hypochlorite (Bleach):** prepare a 5-10 ppm solution in lukewarm water.
- ▶ **70% Ethanol:** immerse the cartridges (Buna N O-rings not compatible).
- ▶ **70% IPA:** immerse the cartridges.
- ▶ **Chlorine Dioxide (ClO₂):** add 2 oz. (59 ml) of Chlorine Dioxide to one gallon (3.79 liters) of lukewarm water (200 ppm).
- ▶ **10% Hydrogen Peroxide:** immerse the cartridges in 10% H₂O₂.
- ▶ **Acid:** immerse the cartridges in 1% solution of citric, acetic, nitric, phosphoric or hydrochloric acid.
- ▶ **Peracetic Acid:** immerse cartridges in 100-200 ppm solution.
- ▶ **Caustic:** rinse cartridges or soak overnight in 0.5-5% NaOH solution. Hot caustic at 122°F (50°C) is even more effective. **Do not use on track etch type polyester membrane cartridges.**

Sterilizing

- ▶ **Hot Water:** raise clean water temperature to 176°F (80°C) and immerse the cartridges with open end up for 30 minutes. **For inline hot water flow, do not exceed 3 psid (.21 bar) pressure drop across the cartridge and 30 minute maximum circulation at stated temperature.**
- ▶ **Steam:** raise the steam temperature to 250°F (121°C) and expose the cartridge to steam for 30 minutes. **For inline hot steam, do not exceed more than 3 psid (.21 bar) pressure drop across the cartridge.***
- ▶ **Autoclave:** install the cartridges in the autoclave chamber. Raise steam temperature to 250°F (121°C) and expose the cartridge for 30 minutes.*

* Cartridge must be equipped with special end cap insert to withstand steaming or autoclaving.

Final Rinse

- ▶ **Final Rinse:** rinse all cleaned and sanitized cartridges with plenty of clean water to remove any remaining cleaning and sanitizing agents.

Note: This publication is to be used as a guide. The data within has been obtained from many sources and is considered to be accurate. Harmsco does not assume liability for the accuracy and/or completeness of this data. Changes to the data can be made without notification. Temperature, Pressure, Flow Rates, Differential Pressures, Chemical Combinations and other unknown factors can affect performance in unknown ways. **Limited Warranty:** Harmsco warrants their products to be free of material and workmanship defects. Determination of suitability of Harmsco products for uses and applications contemplated by Buyer shall be the sole responsibility of Buyer. The end user/installer/buyer shall be liable for the product's performance and suitability regarding their specific intended applications. End users should perform their own tests to determine suitability for each application.